



CITY OF BURLINGTON

ENGINEERING DEPARTMENT

W. Todd Lambert, P.E.
City Engineer

April 1, 2021

ADDENDUM NO. 1

Project: 2021-014 2020 - 2" Waterline Replacement

General

The following changes, additions, interpretations and corrections are herewith made a part of the referenced project and shall take precedence over previous requirements. Contractors shall familiarize themselves with the content of this addendum, as it is a part of the contract documents.

IT SHOULD BE NOTED THAT NO ADDITIONAL BID TIME SHALL BE PROVIDED AS A RESULT OF THIS ADDENDUM AND THE BID DATE REMAINS April 6, 2021 AT 2PM

POINTS OF CLARIFICATION

Driveway repair square yardage will vary by factors including the construction of the individual driveways, as well as the location of the right of way and nearest expansion joint to the construction, and per the direction of the Inspector in the field. No rebar or pinning will be required.

As noted on the plans, the City of Burlington will be resurfacing the asphalt on public roadways. The contractor will be responsible to bring the backfill and stone to the depth required for the asphalt layer.

The City does not anticipate any of the roads have concrete under the asphalt, however it is possible. There may also be concrete patches in the project area.

Staging/laydown areas are not guaranteed. If there is space at City properties, the City may consider allowing material to be stored there. If private land is used, a copy of the agreement should be provided to the City. All roadways and properties must be accessible during construction, per the specifications. Construction material may be placed in the City road right of way in the project area, however it is the contractor's sole responsibility to prevent loss or damage of said materials.

Any references on the drawings to detail "SC-22" should be considered to read "SC-11" instead.

Existing meters and boxes will be reused, if possible. The meters will be provided by the City, if required. The contractor will be required to connect the services after the main has been put into service. Properties in the project area which do not currently have a tap and meter, will not receive a new tap and meter.

While the details M-1 and M-2 list 3 feet of minimum cover for the pipe, the construction plans state that minimum depth shall be 4 feet and that shall govern installation.

Stone, if required for backfill, will be paid for using the incidental stone pay item.

Soil erosion control devices as per the Contractor's operations and shall be paid per the pay item description.

Detail SC-9 refers to a Siamese water service connection and will not be applicable in this project.

END OF ADDENDUM NO. 1